

<b>AMENDMENT OF SOLICITATION/MODIFICATION OF CONTRACT</b>				1. CONTRACT ID CODE <b>J</b>		PAGE OF PAGES <b>1   3</b>	
2. AMENDMENT/MODIFICATION NO. <b>0003</b>		3. EFFECTIVE DATE <b>17-Jun-2003</b>		4. REQUISITION/PURCHASE REQ. NO.		5. PROJECT NO.(If applicable) <b>ED-00-008</b>	
6. ISSUED BY USACE, CONTRACTING DIVISION P.O. BOX 60267 NEW ORLEANS LA 70160-0267		CODE <b>DACW29</b>		7. ADMINISTERED BY (If other than item 6)  <b>See Item 6</b>		CODE	
8. NAME AND ADDRESS OF CONTRACTOR (No., Street, County, State and Zip Code)				X		9A. AMENDMENT OF SOLICITATION NO. <b>DACW29-03-B-0034</b>	
				X		9B. DATED (SEE ITEM 11) <b>10-Feb-2003</b>	
						10A. MOD. OF CONTRACT/ORDER NO.	
						10B. DATED (SEE ITEM 13)	
CODE		FACILITY CODE					
<b>11. THIS ITEM ONLY APPLIES TO AMENDMENTS OF SOLICITATIONS</b>							
<input checked="" type="checkbox"/> The above numbered solicitation is amended as set forth in Item 14. The hour and date specified for receipt of Offer <input checked="" type="checkbox"/> is extended, <input type="checkbox"/> is not extended. Offer must acknowledge receipt of this amendment prior to the hour and date specified in the solicitation or as amended by one of the following methods: (a) By completing Items 8 and 15, and returning <u>1</u> copies of the amendment; (b) By acknowledging receipt of this amendment on each copy of the offer submitted; or (c) By separate letter or telegram which includes a reference to the solicitation and amendment numbers. FAILURE OF YOUR ACKNOWLEDGMENT TO BE RECEIVED AT THE PLACE DESIGNATED FOR THE RECEIPT OF OFFERS PRIOR TO THE HOUR AND DATE SPECIFIED MAY RESULT IN REJECTION OF YOUR OFFER. If by virtue of this amendment you desire to change an offer already submitted, such change may be made by telegram or letter, provided each telegram or letter makes reference to the solicitation and this amendment, and is received prior to the opening hour and date specified.							
12. ACCOUNTING AND APPROPRIATION DATA (If required)							
<b>13. THIS ITEM APPLIES ONLY TO MODIFICATIONS OF CONTRACTS/ORDERS.</b> <b>IT MODIFIES THE CONTRACT/ORDER NO. AS DESCRIBED IN ITEM 14.</b>							
A. THIS CHANGE ORDER IS ISSUED PURSUANT TO: (Specify authority) THE CHANGES SET FORTH IN ITEM 14 ARE MADE IN THE CONTRACT ORDER NO. IN ITEM 10A.							
B. THE ABOVE NUMBERED CONTRACT/ORDER IS MODIFIED TO REFLECT THE ADMINISTRATIVE CHANGES (such as changes in paying office, appropriation date, etc.) SET FORTH IN ITEM 14, PURSUANT TO THE AUTHORITY OF FAR 43.103(B).							
C. THIS SUPPLEMENTAL AGREEMENT IS ENTERED INTO PURSUANT TO AUTHORITY OF:							
D. OTHER (Specify type of modification and authority)							
E. IMPORTANT: Contractor <input type="checkbox"/> is not, <input type="checkbox"/> is required to sign this document and return _____ copies to the issuing office.							
14. DESCRIPTION OF AMENDMENT/MODIFICATION (Organized by UCF section headings, including solicitation/contract subject matter where feasible.) 1. Please review pages 2 & 3 attach and make pen & ink changes to the designated sections of the solicitation. 2. Bid opening has been extended for June 27th 2003 at 14:00 hr CT, New Orleans District, Room 167. 3. Contractor is required to sign and submit signed amendment IAW paragraph (a) above with their bids. 4. No other changes to follow, all other terms and conditions remains the same.							
Except as provided herein, all terms and conditions of the document referenced in Item 9A or 10A, as heretofore changed, remains unchanged and in full force and effect.							
15A. NAME AND TITLE OF SIGNER (Type or print)				16A. NAME AND TITLE OF CONTRACTING OFFICER (Type or print)			
				TEL: EMAIL:			
15B. CONTRACTOR/OFFEROR		15C. DATE SIGNED		16B. UNITED STATES OF AMERICA		16C. DATE SIGNED	
_____ (Signature of person authorized to sign)				BY _____ (Signature of Contracting Officer)		17-Jun-2003	

EXCEPTION TO SF 30  
APPROVED BY OIRM 11-84

30-105-04

STANDARD FORM 30 (Rev. 10-83)  
Prescribed by GSA  
FAR (48 CFR) 53.243

## SECTION SF 30 BLOCK 14 CONTINUATION PAGE

**SECTION 00700**

NOTE: In response to questions from interested parties, the Government would like to emphasize that the Buy American Act applies to this contract. See provisions/clauses 52.225-10, Notice of Buy American Act/Balance of Payments Program Requirement -- Construction Materials found in Section 00100 and 52.225-9, Buy American Act - Construction Materials found in Section 00700 for guidance on this issue.

**SECTION 02332**

1. Page 2, paragraph 1.3.1, 4th line. Replace the 2nd sentence to read the following:

The basis for the measurement will be cross sections of the areas to be filled taken prior to clearing, grubbing, vegetation removal and moisture control operations and the theoretical design sections of the completed levee constructed within the specified tolerance.

2. Page 7, paragraph 1.7.3, 7th line. Rewrite the 5th sentence to read the following:

Borrow material shall not be placed directly upon the levee if it has a moisture content either greater than plus 10 percent or less than minus 10 percentage points of the optimum moisture content resulting from the Standard Proctor density test ASTM D 698.

3. Page 7, paragraph 1.7.3, 10th line. Rewrite the 6th sentence to read the following:

The material must be processed to within 10 percent of optimum moisture content in the borrow area or as prescribed on the plans before it may be placed upon the levee for final processing.

**SECTION 02922**

1. Page 1, paragraph 1.3. Insert the following at the end of the paragraph: "No measurement will be made for fertilizing, seeding and mulching areas disturbed as a result of moisture control operations within Typical Section 2 as shown on the drawings."
2. Page 1, paragraph 1.4. Insert the following at the end of the paragraph: "No payment will be made for fertilizing, seeding and mulching areas disturbed as a result of moisture control operations within Typical Section 2 as shown on the drawings."

**DRAWINGS**

## 1. Dwg 5 of 31:

Insert the following in the lower portion of Block C2 and below TYPICAL SECTION 2:

NOTE A: MOISTURE CONTROL OPERATIONS WILL NOT BE PERMITTED W/IN 10 FT OF THE NEW COMPACTED EMBANKMENT FOOTPRINT AND SHALL NOT EXCEED A LIMIT DEFINED AS 20 FT LEVEESIDE OF THE EXISTING HWY 997 DRAINAGE DITCH. NO MOISTURE CONTROL

OPERATIONS WILL BE PERMITTED ON THE FLOODSIDE OF THE LEVEE. MOISTURE CONTROL OPERATIONS SHALL NOT BLOCK THE EXISTING ACCESS RAMP IN THE VICINITY OF B/L STA 3220+00.

NOTE B: ALL AREAS USED FOR MOISTURE CONTROL OPERATIONS SHALL BE RESTORED TO ORIGINAL CONDITIONS AND SHALL BE FERTILIZED AND SEEDED UPON COMPLETION OF OPERATIONS.

## 2. Dwg 6 of 31:

- a). On both TYPICAL SECTIONS 6 and 7, add settlement gage symbols on the existing ground in the regions of the uncompacted fill with a note attached stating:

“OPTIONAL SETTLEMENT GAGE (SEE DETAILS, DWG 9)”

- b). In the NOTES in the lower right corner of the drawing, modify Note 2 to read:

“COMPACTED FILL MUST BE CONSTRUCTED TO ELEV. 16.0 PRIOR TO PLACING UNCOMPACTED BERM FILL. UNCOMPACTED FILL BERMS SHALL BE COMPLETED PRIOR TO CONSTRUCTION OF COMPACTED FILL ABOVE ELEV 16.0.”

- c). Insert the following note to the NOTES in the lower right corner of the drawing:

“4. MOISTURE CONTROL OPERATIONS WILL NOT BE PERMITTED WITHIN 10 FT OF THE NEW COMPACTED FILL AND SHALL NOT EXCEED THE LIMITS OF FERTILIZING AND SEEDING SHOWN HEREIN.”

(End of Summary of Changes)